

Written Program Indoor Air Quality Standard - PEOSH
Indoor Air Quality Survey & Testing for Sick Building Syndrome
Remediation/Cleanup of Mold & Moisture Problems in Schools & Commercial Buildings
Indoor Air Quality in Schools Awareness Training for Administrative/Maintenance Personnel
Asbestos Surveys and AHERA Management Plans
AHERA 2 Hour Awareness Training
"Non-Friable" Asbestos Final Air Clearance Sampling
Right to Know Survey, Compliance & PEOSHA Training
Written Hazard Communication Program (PEOSHA HCS)

RAMM Environmental Services, Inc.

Commitment, Excellence, Integrity

77 Nottingham Road, PO Box 308
Fair Lawn, New Jersey 07410
Phone: (201) 475-9880
Fax: (201) 475-9881

July 10, 2024

WP Child Development Center
1800 Valley Road
Wayne, NJ 07470
Attn.: Cindy Gennarelli
Director

**Re: Lead in Drinking Water Analysis at William Paterson University Child
Development Center**

Dear Cindy:

Pursuant to your request, in regard to the above referenced subject, **RAMM Environmental Services, Inc.** is pleased to submit to you our report including findings, analysis and recommendations.

Should you have any questions or need additional information, please feel free to call upon me at (201) 475-9880. Thank you very much.

Respectfully submitted,
RAMM Environmental Services, Inc.

Rodger Headrick

Rodger Headrick, CMRS
President

fh

Written Program Indoor Air Quality Standard - PEOSH
Indoor Air Quality Survey & Testing for Sick Building Syndrome
Remediation/Cleanup of Mold & Moisture Problems in Schools & Commercial Buildings
Indoor Air Quality in Schools Awareness Training for Administrative/Maintenance Personnel
Asbestos Surveys and AHERA Management Plans
AHERA 2 Hour Awareness Training
"Non-Friable" Asbestos Final Air Clearance Sampling
Right to Know Survey, Compliance & PEOSHA Training
Written Hazard Communication Program (PEOSHA HCS)

RAMM Environmental Services, Inc.

Commitment, Excellence, Integrity

77 Nottingham Road, PO Box 308
Fair Lawn, New Jersey 07410
Phone: (201) 475-9880
Fax: (201) 475-9881

**LEAD IN DRINKING WATER ANALYSIS
FOR
WILLIAM PATERSON UNIVERSITY
CHILD DEVELOPMENT CENTER
WAYNE, NEW JERSEY
JUNE 18, 2024**

**Prepared for:
WP Child Development Center
1800 Valley Road
Wayne, NJ 07470
Attn.: Cindy Gennarelli
Director
Tel: (973) 720-2529
Fax: (973) 720-3467**

**Prepared by:
RAMM Environmental Services, Inc.
77 Nottingham Road, PO Box 308
Fair Lawn, NJ 07410
Mr. Rodger Headrick
President
Tel: (201) 475-9880
Fax: (201) 475-9881**

July 10, 2024

REPORT CONTENTS

INTRODUCTION	1
WATER QUALITY MONITORING RESULTS	2
RECOMMENDATIONS	3
APPENDIX	
Lead in Drinking Water Certificate of Analysis	

INTRODUCTION

RAMM Environmental Services, Inc. was requested by the William Paterson University Child Development Center to perform water sampling for lead content at the William Paterson University Child Development Center located in Wayne, New Jersey.

Water quality sampling functions were performed by RAMM at the William Paterson University Child Development Center located in Wayne, New Jersey on June 18, 2024, to determine the quality of drinking water for lead content. Water sampling began in the morning after all water outlets had remained unused for a minimum of eight (8) hours.

**WATER QUALITY MONITORING RESULTS
LEAD IN DRINKING WATER ANALYSIS**

Lead in drinking water sampling was performed during RAMM’s June 18, 2024 site visit. The (E.P.A.) Environmental Protection Agency has established an enforceable lead concentration action level for public water supplies. The lead action level is 15 micrograms per liter (mg/L) = parts per billion (ppb), which is equivalent to 0.015 milligrams per liter (mg/L) = parts per million (ppm).

William Paterson University Child Development Center

Lead in drinking water measurements were collected in thirteen (13) locations of the building.

<i>Sample #</i>	<i>Location</i>	<i>Lead Concentration</i>
Field Blank	Field Blank	None Detected
24-0618-01	Kitchen (Sink)	None Detected
24-0618-02	Room 120 (Sink)	None Detected
24-0618-03	Room 122 (Sink)	None Detected
24-0618-04	Hallway by Room 120 (Water Fountain)	None Detected
24-0618-05	Room 123 (Sink)	None Detected
24-0618-06	Nurse Room (Sink)	None Detected
24-0618-07	Room 125 (Sink on Left)	None Detected
24-0618-08	Room 125 (Sink on Right)	None Detected
24-0618-09	Room 129 (Sink on Right)	None Detected
24-0618-10	Room 129 (Sink on Left)	None Detected
24-0618-11	Hallway by Room 129 (Water Fountain)	None Detected
24-0618-12	Room 131 (Sink on Left)	None Detected
24-0618-13	Room 131 (Sink on Right)	3.26 ppb

All results report less than the United States Environmental Protection Agency (U.S.E.P.A.) Guidelines and the New Jersey Department of Environmental Protection (N.J.D.E.P.) for safe drinking water (15 ppb). Currently the drinking water is safe and poses no health hazard to building occupants.

RECOMMENDATIONS

Continue operation and maintenance as normal. Re-test all drinking water outlets during the 2027-2028 school year.